

**BLOCK WATER TESTING LABORATORY, BATALA**

Judicial Court Complex on Police line Road, Opposite Police Station, Batala.  
bwtlbt@gmail.com

To,

Bhai Amrik Singh Khalsa Academy  
Qadian


No.: BWTBTL/2526/00047 Dated : 29/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 265 Dated: 26/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 26/05/2025. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Batala

D/A : Test Report



Authorized Signatory  
For, Block Water Testing Laboratory  
Batala



Director  
BHA AMRIK SINGH JI  
KHALSA ACADEMY  
V.P.O. Manesh, Gurdaspur

# BLOCK WATER TESTING LABORATORY, BATALA


Judicial Court Complex on Police line Road, Opposite Police Station, Batala.  
bwtlbt@gmail.com

TEST REPORT						
Name & Address of Customer : <b>Bhai Amrik Singh Khalsa Academy Qadian</b>			Customer Reference No.		No : 265 Dated : 26/05/2025	
			Sample Submitted by		Balwinder Singh-JE	
			Date of Sample Receipt		26/05/2025	
			Analysis Starting Date		28/05/2025	
			Analysis completion Date		29/05/2025	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:		NABLDWT0026025094F		Sample Type :		Water
Test Report No.:		BWTBTL/2526/00047		Date of Issue :		29/05/2025
Registration no.:		BWTBTL/REG2526/00130		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		NA / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.21	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	40	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	20	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	16	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	4.80	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.972	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	5.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep Kumar  
Quality Manager  
Authorized Signatory  
For, Block Water Testing Laboratory  
Batala

----- End of the Test Report -----



Director  
BHAIRAM SINGH JI  
KHALSA ACADEMY  
V.P.O. Manesh, Gurdaspur